

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WOOD CREEK WATER)	
DISTRICT FOR A DEVIATION FROM 807 KAR)	CASE NO. 94-063
5:066, SECTION 10(2)(A))	

O R D E R

On February 14, 1994, Wood Creek Water District ("Wood Creek") applied for a deviation from Commission Regulation 807 KAR 5:066, Section 10(2)(a), to permit approximately 4,080 feet of existing two-inch water main to remain in service. Commission Regulation 807 KAR 5:066, Section 10(2)(a), establishes the maximum length of individual small pipe.

Having reviewed the evidence of record and being otherwise sufficiently advised, the Commission finds that:

1. Wood Creek currently operates approximately 4,080 linear feet of two-inch water main running along Cabin Creek Road in Laurel County, Kentucky.

2. Commission Regulation 807 KAR 5:066, Section 10(2)(a), prohibits individual non-circulating small pipe of two inch nominal size from exceeding 250 feet in length, but permits deviations from this prohibition for rural water lines which comply with the requirements of Commission Regulation 807 KAR 5:066, Section 5(1), and can provide adequate water flow to serve its customers' peak requirements.

3. Wood Creek states that the water line ends near Wood Creek Lake preventing further expansion.

4. Wood Creek has filed information that indicates that adequate service is presently being provided on this 2-inch water line.

IT IS THEREFORE ORDERED that:

1. Wood Creek is granted a deviation from Commission Regulation 807 KAR 5:066, Section 10(2)(a), for the 4,080 linear feet of water main on Cabin Creek Road. This deviation is contingent upon this water main providing adequate and reliable service in compliance with all other Commission regulations.

2. Wood Creek shall monitor the adequacy of this water main. If the level of service on this water main is inadequate or declining, or its water pressure is outside the limits of Commission Regulation 807 KAR 5:066, Section 5(1), Wood Creek shall take necessary actions to maintain the level of service within the standards set forth in Commission regulations.

3. Wood Creek shall provide service on this water main or any other water main to any customer who is entitled to service under Commission regulations and Wood Creek's tariff.


4. No further extension of or lateral connection to the water main on Cabin Creek Road shall be made unless a minimum of three-inch water line is used.


5. Wood Creek shall construct no further extension or lateral to the water main on Cabin Creek Road until appropriate

engineering studies are performed and all requisite approvals are obtained.

Done at Frankfort, Kentucky, this 22nd day of April, 1994.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director